




## Ribbon Test Points – Built-In Refrigeration




Depress Keyboard pad and test for continuity at all 3 test points.

Example: Depress “FRZ TEMP” on Bottom Mount control panel. Closed contacts 1 & 3, 1 & 6 and 3 & 6 when FRZ TEMP pad is depressed indicates a good switch contact. It should read open when released.

| BOTTOM MOUNT  |   |  |   |   |   |   |   |   |            |
|---------------|---|--|---|---|---|---|---|---|------------|
| Contacts      | 1 |  | 3 | 4 | 5 | 6 | 7 | 8 | Total      |
| DISPLAY ON    | X |  | X | X |   |   |   |   | 1, 3 and 4 |
| FRZ TEMP      | X |  | X |   |   | X |   |   | 1, 3 and 6 |
| REF TEMP      | X |  | X |   |   |   | X |   | 1, 3 and 7 |
| HIGHER TEMP   | X |  |   |   |   | X | X |   | 1, 6 and 7 |
| LOWER TEMP    | X |  |   | X |   | X |   |   | 1, 4 and 6 |
| DISPLAY       |   |  |   |   |   |   |   |   |            |
| HIDDEN BUTTON | X |  |   | X |   |   | X |   | 1, 4 and 7 |
| MAX REF       | X |  |   |   |   |   | X | X | 1, 7 and 8 |
| MAX FRZ       | X |  |   | X |   |   |   | X | 1, 4 and 8 |
| ALARM OFF     | X |  |   |   | X | X |   |   | 1, 5 and 6 |
| DISPLAY OFF   | X |  |   |   |   | X |   | X | 1, 6 and 8 |

| SIDE BY SIDE  |   |  |   |   |   |   |   |   |            |
|---------------|---|--|---|---|---|---|---|---|------------|
| Contacts      | 1 |  | 3 | 4 | 5 | 6 | 7 | 8 | Total      |
| DISPLAY       |   |  |   |   |   |   |   |   |            |
| DISPLAY ON    | X |  | X | X |   |   |   |   | 1, 3 and 4 |
| FRZ TEMP      | X |  | X |   |   | X |   |   | 1, 3 and 6 |
| REF TEMP      | X |  | X |   |   |   | X |   | 1, 3 and 7 |
| HIGHER TEMP   | X |  |   |   |   | X | X |   | 1, 6 and 7 |
| LOWER TEMP    | X |  |   | X |   | X |   |   | 1, 4 and 6 |
| HIDDEN BUTTON | X |  |   | X |   |   | X |   | 1, 4 and 7 |
| MAX REF       | X |  |   |   |   |   | X | X | 1, 7 and 8 |
| MAX FRZ       | X |  |   | X |   |   |   | X | 1, 4 and 8 |
| ALARM OFF     | X |  |   | X | X |   |   |   | 1, 4 and 5 |
| DISPLAY OFF   | X |  |   |   | X |   |   | X | 1, 5 and 8 |



Depress Keyboard pad and test for continuity at all 3 test points.

Example: Depress "ALARM OFF" on All Freezer control panel. Closed contacts 1 & 4, 1 & 5 and 4 & 5 when ALARM OFF pad is depressed indicates a good switch contact. It should read open when released.

| ALL FREEZER      |   |  |   |   |   |   |   |   |            |
|------------------|---|--|---|---|---|---|---|---|------------|
| Contacts         | 1 |  | 3 | 4 | 5 | 6 | 7 | 8 | Total      |
| DISPLAY ON       | X |  | X | X |   |   |   |   | 1, 3 and 4 |
| FRZ TEMP         | X |  | X |   |   | X |   |   | 1, 3 and 6 |
| HIGHER TEMP      | X |  |   |   |   | X | X |   | 1, 6 and 7 |
| LOWER TEMP       | X |  |   | X |   | X |   |   | 1, 4 and 6 |
| HIDDEN BUTTON    | X |  |   | X |   |   | X |   | 1, 4 and 7 |
| DISPLAY          |   |  |   |   |   |   |   |   |            |
| MAX REF (Hidden) | X |  |   |   |   |   | X | X | 1, 7 and 8 |
| MAX FRZ          | X |  |   | X |   |   |   | X | 1, 4 and 8 |
| ALARM OFF        | X |  |   | X | X |   |   |   | 1, 4 and 5 |
| DISPLAY OFF      | X |  |   |   | X |   |   | X | 1, 5 and 8 |

| ALL REFRIG       |   |  |   |   |   |   |   |   |            |
|------------------|---|--|---|---|---|---|---|---|------------|
| Contacts         | 1 |  | 3 | 4 | 5 | 6 | 7 | 8 | Total      |
| DISPLAY ON       | X |  | X | X |   |   |   |   | 1, 3 and 4 |
| REF TEMP         | X |  | X |   |   |   | X |   | 1, 3 and 7 |
| HIGHER TEMP      | X |  |   |   |   | X | X |   | 1, 6 and 7 |
| LOWER TEMP       | X |  |   | X |   | X |   |   | 1, 4 and 6 |
| HIDDEN BUTTON    | X |  |   | X |   |   | X |   | 1, 4 and 7 |
| DISPLAY          |   |  |   |   |   |   |   |   |            |
| MAX FRZ (Hidden) | X |  |   | X |   |   |   | X | 1, 4 and 8 |
| MAX REF          | X |  |   |   |   |   | X | X | 1, 7 and 8 |
| ALARM OFF        | X |  |   | X | X |   |   |   | 1, 4 and 5 |
| DISPLAY OFF      | X |  |   |   | X |   |   | X | 1, 5 and 8 |